

# Previous Data on the Radiation Level of Purified Water at Main Water Purification Plants of Tokyo Waterworks in January

The previous results on purified water in January are as follows.

## 1 Kanamachi Purification Plant (Edogawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine (Iodine131)	Radioactive Cesium (Cesium134)	Radioactive Cesium (Cesium137)
2012/1/1	ND (Detection Limit 0.8 )	ND (Detection Limit 0.6 )	ND (Detection Limit 0.9 )
2012/1/2	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/3	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )
2012/1/4	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/5	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/6	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/7	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/8	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 1 )
2012/1/9	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )
2012/1/10	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/11	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/12	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/13	ND (Detection Limit 0.7 )	ND (Detection Limit 1 )	ND (Detection Limit 0.9 )
2012/1/14	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/15	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/16	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/17	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/18	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/19	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/20	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/21	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/22	ND (Detection Limit 0.6 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/23	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/24	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/25	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/26	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 1 )
2012/1/27	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/28	ND (Detection Limit 0.8 )	ND (Detection Limit 0.6 )	ND (Detection Limit 0.9 )
2012/1/29	ND (Detection Limit 0.7 )	ND (Detection Limit 0.6 )	ND (Detection Limit 0.9 )
2012/1/30	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/31	ND (Detection Limit 0.7 )	ND (Detection Limit 0.4 )	ND (Detection Limit 0.8 )

1 Sampling time : 6:00 A.M.

2 Testing institute : Water Quality Management Center

3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 0.8)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 0.8 Bq/kg, but the concentration of radioactive particles in the sample was less than 0.8 Bq/kg. Cases such as this are listed in the above chart as “ND”.

## 2 Asaka Purification Plant (Arakawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine (Iodine131)	Radioactive Cesium (Cesium134)	Radioactive Cesium (Cesium137)
2012/1/1	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )
2012/1/2	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/3	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/4	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )
2012/1/5	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/6	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/7	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/8	ND (Detection Limit 0.6 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/9	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )	ND (Detection Limit 1 )
2012/1/10	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )
2012/1/11	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 1 )
2012/1/12	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/13	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/14	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/15	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/16	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/17	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/18	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/19	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/20	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/21	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/22	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/23	ND (Detection Limit 0.6 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/24	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/25	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 1 )
2012/1/26	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/27	ND (Detection Limit 0.8 )	ND (Detection Limit 1 )	ND (Detection Limit 0.9 )
2012/1/28	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/29	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/30	ND (Detection Limit 0.7 )	ND (Detection Limit 1 )	ND (Detection Limit 0.9 )
2012/1/31	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

1 Sampling time : 6:00 A.M.

2 Testing institute : Water Quality Management Center

3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 0.8)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 0.8 Bq/kg, but the concentration of radioactive particles in the sample was less than 0.8 Bq/kg. Cases such as this are listed in the above chart as “ND”.

### 3 Ozaku Purification Plant (Tamagawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine (Iodine131)	Radioactive Cesium (Cesium134)	Radioactive Cesium (Cesium137)
2012/1/1	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/2	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/3	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )
2012/1/4	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/5	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/6	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )
2012/1/7	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/8	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )
2012/1/9	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/10	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )
2012/1/11	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/12	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/13	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/14	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/15	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/16	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/17	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )
2012/1/18	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/19	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/20	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )
2012/1/21	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )
2012/1/22	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/23	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/24	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/25	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/26	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/27	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/28	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/29	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/30	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/31	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

1 Sampling time : 6:00 A.M.

2 Testing institute : Water Quality Management Center

3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 0.8)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 0.8 Bq/kg, but the concentration of radioactive particles in the sample was less than 0.8 Bq/kg. Cases such as this are listed in the above chart as “ND”.

#### 4 Higashi-murayama Purification Plant (Arakawa River, Tamagawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine (Iodine131)	Radioactive Cesium (Cesium134)	Radioactive Cesium (Cesium137)
2012/1/1	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/2	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/3	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/4	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/5	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/6	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/7	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/8	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/9	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/10	ND (Detection Limit 0.6 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )
2012/1/11	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/12	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/13	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/14	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/15	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/16	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/17	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 1 )
2012/1/18	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/19	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/20	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/21	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/22	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/23	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/24	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/25	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )
2012/1/26	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/27	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/28	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/29	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )
2012/1/30	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/31	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.6 )

1 Sampling time : 6:00 A.M.

2 Testing institute : Water Quality Management Center

3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 0.8)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 0.8 Bq/kg, but the concentration of radioactive particles in the sample was less than 0.8 Bq/kg. Cases such as this are listed in the above chart as “ND”.

## 5 Nagasawa Purification Plant (Sagamigawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine (Iodine131)	Radioactive Cesium (Cesium134)	Radioactive Cesium (Cesium137)
2012/1/1	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/2	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/3	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/4	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 1 )
2012/1/5	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )
2012/1/6	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/7	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/8	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/9	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/10	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )
2012/1/11	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/12	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )
2012/1/13	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/14	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/15	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/16	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/17	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/18	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/19	ND (Detection Limit 0.6 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/20	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/21	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/22	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 1 )
2012/1/23	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/24	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 1 )
2012/1/25	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/26	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/27	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )
2012/1/28	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )
2012/1/29	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/30	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/31	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.5 )

1 Sampling time : 6:00 A.M.

2 Testing institute : Water Quality Management Center

3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 0.8)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 0.8 Bq/kg, but the concentration of radioactive particles in the sample was less than 0.8 Bq/kg. Cases such as this are listed in the above chart as “ND”.

## 6 Misato Purification Plant (Edogawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2012/1/2	ND (Detection Limit 0.5 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.6 )
2012/1/9	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/16	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 1 )
2012/1/23	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/24	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )

- 1 Sampling time : 9:00 A.M.
- 2 Testing institute : Water Quality Management Center
- 3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 0.8)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 0.8 Bq/kg, but the concentration of radioactive particles in the sample was less than 0.8 Bq/kg. Cases such as this are listed in the above chart as “ND”.

## 7 Misono Purification Plant (Arakawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2012/1/3	ND (Detection Limit 0.6 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )
2012/1/10	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2012/1/17	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/24	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )

- 1 Sampling time : 9:00 A.M.
- 2 Testing institute : Water Quality Management Center
- 3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 0.8)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 0.8 Bq/kg, but the concentration of radioactive particles in the sample was less than 0.8 Bq/kg. Cases such as this are listed in the above chart as “ND”.

## 8 Sakai Purification Plant (Tamagawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2012/1/4	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/11	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.7 )
2012/1/18	ND (Detection Limit 0.7 )	ND (Detection Limit 0.6 )	ND (Detection Limit 0.8 )
2012/1/25	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )	ND (Detection Limit 1 )

1 Sampling time : 9:00 A.M.

2 Testing institute : Water Quality Management Center

3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 0.8)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 0.8 Bq/kg, but the concentration of radioactive particles in the sample was less than 0.8 Bq/kg. Cases such as this are listed in the above chart as “ND”.

## 9 Kinuta Purification Plant (Tamagawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2012/1/5	ND (Detection Limit 0.7 )	ND (Detection Limit 0.5 )	ND (Detection Limit 0.7 )
2012/1/12	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/19	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2012/1/26	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

1 Sampling time : 9:00 A.M.

2 Testing institute : Water Quality Management Center

3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 0.8)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 0.8 Bq/kg, but the concentration of radioactive particles in the sample was less than 0.8 Bq/kg. Cases such as this are listed in the above chart as “ND”.

## 9 Kinutashimo Purification Plant (Tamagawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2012/1/6	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )
2012/1/13	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )
2012/1/20	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2012/1/27	ND (Detection Limit )	ND (Detection Limit )	ND (Detection Limit )

1 Sampling time : 9:00 A.M.

2 Testing institute : Water Quality Management Center

3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 0.8)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 0.8 Bq/kg, but the concentration of radioactive particles in the sample was less than 0.8 Bq/kg. Cases such as this are listed in the above chart as “ND”.

### 【Reference】

(Bq/kg)

	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium
Japanese provisional (emergency) criteria for infants	100	Not specified
Japan provisional (emergency) criteria for all except infants *1	300	200

\*1 Criteria value related to radioactive elements ingestion from food and drink set by Nuclear Safety Commission