

Previous Data on the Radiation Level of Purified Water at Water Purification Plants of Tokyo Waterworks in July

The previous results on purified water in July are as follows.

1 Kanamachi Purification Plant (Edogawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine (Iodine131)	Radioactive Cesium (Cesium134)	Radioactive Cesium (Cesium137)
2011/7/1	ND (Detection Limit 6)	ND (Detection Limit 5)	ND (Detection Limit 7)
2011/7/2	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 8)
2011/7/3	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/4	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 8)
2011/7/5	ND (Detection Limit 6)	ND (Detection Limit 8)	ND (Detection Limit 8)
2011/7/6	ND (Detection Limit 6)	ND (Detection Limit 5)	ND (Detection Limit 7)
2011/7/7	ND (Detection Limit 6)	ND (Detection Limit 5)	ND (Detection Limit 7)
2011/7/8	ND (Detection Limit 7)	ND (Detection Limit 7)	ND (Detection Limit 8)
2011/7/9	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 8)
2011/7/10	ND (Detection Limit 5)	ND (Detection Limit 6)	ND (Detection Limit 8)
2011/7/11	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 8)
2011/7/12	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/13	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 8)
2011/7/14	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/15	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 6)
2011/7/16	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/17	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/18	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/19	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/20	ND (Detection Limit 5)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/21	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/22	ND (Detection Limit 6)	ND (Detection Limit 5)	ND (Detection Limit 6)
2011/7/23	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/24	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/25	ND (Detection Limit 5)	ND (Detection Limit 6)	ND (Detection Limit 6)
2011/7/26	ND (Detection Limit 5)	ND (Detection Limit 5)	ND (Detection Limit 6)
2011/7/27	ND (Detection Limit 6)	ND (Detection Limit 5)	ND (Detection Limit 7)
2011/7/28	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/29	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 6)
2011/7/30	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/31	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 6)

※1 Sampling time : 6:00 A.M.

※2 Testing institute : Tokyo Metropolitan Industrial Technology Research Institute

※3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 6)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 6 Bq/kg, but the concentration of radioactive particles in the sample was less than 6 Bq/kg. Cases such as this are listed in the above chart as “ND”.

2 Asaka Purification Plant (Arakawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine (Iodine131)	Radioactive Cesium (Cesium134)	Radioactive Cesium (Cesium137)
2011/7/1	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/2	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/3	ND (Detection Limit 6)	ND (Detection Limit 5)	ND (Detection Limit 8)
2011/7/4	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/5	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/6	ND (Detection Limit 5)	ND (Detection Limit 6)	ND (Detection Limit 8)
2011/7/7	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 8)
2011/7/8	ND (Detection Limit 7)	ND (Detection Limit 6)	ND (Detection Limit 8)
2011/7/9	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 8)
2011/7/10	ND (Detection Limit 6)	ND (Detection Limit 4)	ND (Detection Limit 7)
2011/7/11	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 8)
2011/7/12	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/13	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/14	ND (Detection Limit 5)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/15	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/16	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 5)
2011/7/17	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 6)
2011/7/18	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/19	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/20	ND (Detection Limit 5)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/21	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/22	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/23	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/24	ND (Detection Limit 6)	ND (Detection Limit 5)	ND (Detection Limit 7)
2011/7/25	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 6)
2011/7/26	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/27	ND (Detection Limit 6)	ND (Detection Limit 4)	ND (Detection Limit 6)
2011/7/28	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/29	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/30	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/31	ND (Detection Limit 5)	ND (Detection Limit 6)	ND (Detection Limit 7)

※1 Sampling time : 6:00 A.M.

※2 Testing institute : Tokyo Metropolitan Industrial Technology Research Institute

※3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 6)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 6 Bq/kg, but the concentration of radioactive particles in the sample was less than 6 Bq/kg. Cases such as this are listed in the above chart as “ND”.

3 Ozaku Purification Plant (Tamagawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine (Iodine131)	Radioactive Cesium (Cesium134)	Radioactive Cesium (Cesium137)
2011/7/1	ND (Detection Limit 6)	ND (Detection Limit 5)	ND (Detection Limit 8)
2011/7/2	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/3	ND (Detection Limit 6)	ND (Detection Limit 5)	ND (Detection Limit 7)
2011/7/4	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/5	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 8)
2011/7/6	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 9)
2011/7/7	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/8	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 8)
2011/7/9	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/10	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 8)
2011/7/11	ND (Detection Limit 5)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/12	ND (Detection Limit 7)	ND (Detection Limit 7)	ND (Detection Limit 8)
2011/7/13	ND (Detection Limit 6)	ND (Detection Limit 5)	ND (Detection Limit 7)
2011/7/14	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/15	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/16	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/17	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 5)
2011/7/18	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/19	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/20	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 6)
2011/7/21	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 5)
2011/7/22	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/23	ND (Detection Limit 7)	ND (Detection Limit 7)	ND (Detection Limit 7)
2011/7/24	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)
2011/7/25	ND (Detection Limit 5)	ND (Detection Limit 5)	ND (Detection Limit 7)
2011/7/26	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 5)
2011/7/27	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 5)
2011/7/28	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 6)
2011/7/29	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 5)
2011/7/30	ND (Detection Limit 6)	ND (Detection Limit 6)	ND (Detection Limit 7)
2011/7/31	ND (Detection Limit 6)	ND (Detection Limit 7)	ND (Detection Limit 6)

※1 Sampling time : 6:00 A.M.

※2 Testing institute : Tokyo Metropolitan Industrial Technology Research Institute

※3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 6)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 6 Bq/kg, but the concentration of radioactive particles in the sample was less than 6 Bq/kg. Cases such as this are listed in the above chart as “ND”.

4 Higashi-murayama Purification Plant (Arakawa River, Tamagawa River)

(Bq/kg)

Sampling Date	Radioactive Iodine (Iodine131)	Radioactive Cesium (Cesium134)	Radioactive Cesium (Cesium137)
2011/7/1	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 3)
2011/7/2	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/3	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/4	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/5	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/6	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/7	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/8	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/9	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/10	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/11	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/12	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/13	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/14	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/15	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/16	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/17	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/18	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/19	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/20	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/21	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/22	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/23	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/24	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/25	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/26	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 3)
2011/7/27	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/28	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/29	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/30	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/31	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)

※1 Sampling time : 6:00 A.M.

※2 Testing institute : Tokyo Metropolitan University

※3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 6)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 6 Bq/kg, but the concentration of radioactive particles in the sample was less than 6 Bq/kg. Cases such as this are listed in the above chart as “ND”.

5 Nagasawa Purification Plant (Sagamigawa River)

Purified water at Nagasawa Purification Plant has been tested since July 15th, 2011, when the plant revived operation after the construction.

(Bq/kg)

Sampling Date	Radioactive Iodine (Iodine131)	Radioactive Cesium (Cesium134)	Radioactive Cesium (Cesium137)
2011/7/15	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/16	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/17	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/18	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/19	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/20	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/21	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/22	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/23	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/24	ND (Detection Limit 3)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/25	ND (Detection Limit 3)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/26	ND (Detection Limit 2)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/27	ND (Detection Limit 3)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/28	ND (Detection Limit 3)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/29	ND (Detection Limit 3)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/30	ND (Detection Limit 3)	ND (Detection Limit 2)	ND (Detection Limit 2)
2011/7/31	ND (Detection Limit 3)	ND (Detection Limit 2)	ND (Detection Limit 2)

※1 Sampling time : 6:00 A.M.

※2 Testing institute : Tokyo Metropolitan University

※3 ND (Not detectable) : “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 6)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 6 Bq/kg, but the concentration of radioactive particles in the sample was less than 6 Bq/kg. Cases such as this are listed in the above chart as “ND”.

【Reference】

(Bq/kg)

	Radioactive Iodine (Iodine 131)	Radioactive Cesium
Japanese provisional (emergency) criteria for infants	100	Not specified
Japan provisional (emergency) criteria for all except infants *1	300	200

*1 Criteria value related to radioactive elements ingestion from food and drink set by Nuclear Safety Commission