

Previous Data on the Radiation Level of Purified Water at Water Purification Plants in Tama Area in November

Purified water at Sugunami Purification Plant has been tested since November 9th, 2011, when the plant revived operation after the construction.

1 Kamirenjyaku Purification Plant (groundwater)

Address: 9-41-4, Kamirenjyaku, Mitaka city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/1	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)	ND (Detection Limit 0.8)
2011/11/29	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)

2 Mitakashinkawa Purification Plant (groundwater)

Address: 2-1-15, Shinkawa, Mikata city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/1	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)
2011/11/29	ND (Detection Limit 0.8)	ND (Detection Limit 0.6)	ND (Detection Limit 0.8)

3 Kamiishihara Purification Plant (groundwater)

Address: 1-34, Kamiishihara, Chofu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/1	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)
2011/11/29	ND (Detection Limit 0.8)	ND (Detection Limit 0.7)	ND (Detection Limit 0.9)

4 Yaho Purification Plant (groundwater)

Address: 1462-1, Yaho, Kunitachi city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/2	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)
2011/11/30	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)

5 Kunitachinaka Purification Plant (groundwater)

Address: 3-8-1, Naka, Kunitachi city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/2	ND (Detection Limit 0.8)	ND (Detection Limit 0.7)	ND (Detection Limit 0.9)
2011/11/30	ND (Detection Limit 0.7)	ND (Detection Limit 0.6)	ND (Detection Limit 0.8)

6 Fuchumusashidai Purification Plant (groundwater)

Address: 2-7, Musashidai, Fuchu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/2	ND (Detection Limit 0.7)	ND (Detection Limit 0.9)	ND (Detection Limit 0.9)
2011/11/30	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)

7 Misawa Purification Plant (groundwater)

Address: 1-19-1,Misawa, Hino city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/3	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)	ND (Detection Limit 1)

8 Osakaue Purification Plant (groundwater)

Address: 1-17-11,Osakaue, Hino city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/3	ND (Detection Limit 0.9)	ND (Detection Limit 0.9)	ND (Detection Limit 0.9)

9 Minamidaira Purification Plant (groundwater)

Address: 2-24-5,Minamidaira, Hino city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/3	ND (Detection Limit 0.9)	ND (Detection Limit 0.7)	ND (Detection Limit 1)

10 Sakuragaoka Purification Plant (groundwater)

Address: 4-10, Sakuragaoka, Tama city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/4	ND (Detection Limit 0.8)	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)

11 Omaru Purification Plant (groundwater)

Address: 760,Omaru,Inagi city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/4	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)

12 Sakahama Purification Plant (groundwater)

Address: 816,Sakahama,Inagi city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/4	ND (Detection Limit 0.8)	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)

13 Kamiyotsugi Purification Plant (groundwater)

Address: 407, Kamiyotsugi, Akiruno city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/7	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)

14 Hussamusashinodai Purification Plant (groundwater)

Address:2- 32, Musashinodai, Husa city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/7	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)	ND (Detection Limit 1)

15 Akatsukicho Purification Plant (groundwater)

Address: 1-7-12,Akatsukicho, Hachioji city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/7	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)

16 Ogouchi Purification Plant (Tamagawa River)

Address:1310-10,Tozura-aza-Amefuri,Okutama town

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/8	ND (Detection Limit 0.7)	ND (Detection Limit 0.9)	ND (Detection Limit 0.9)

17 Sawaidaiichi Purification Plant (subsoil water)

Address: 1-535-3,Sawai, Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/8	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)	ND (Detection Limit 0.8)

18 Sawaidaini Purification Plant (subsoil water)

Address: 3-667,Sawai,Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/8	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)

19 Jyosuiminami Plant (groundwater)

Address: 3-12-36, Jyosuiminami-cho, Kodaira city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/9	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)

20 Kajino Purification Plant (groundwater)

Address: 5-10-33,kajinocho, Koganei city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/9	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)

21 Suginami Purification Plant (groundwater)

Address: 5-10-33,kajinocho, Koganei city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/9	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)	ND (Detection Limit 0.9)

22 Saiwaimachi Purification Plant (groundwater)

Address: 2-24, Saiwai-cho, Huchu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/10	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)

23 Wakamatsu Purification Plant (groundwater)

Address: 4-10,Wakamatsucho, Fuchu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/10	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)

24 Fuchuminamicho Purification Plant (groundwater)

Address: 1-50,Minami-cho, Fuchu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/10	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)

25 Shibasaki Purification Plant (groundwater)

Address: 1-1-41,Shibasakicho, Tachikawa city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/11	ND (Detection Limit 0.9)	ND (Detection Limit 0.7)	ND (Detection Limit 0.9)

26 Fujimidaichi Purification Plant (groundwater)

Address: 1-27-12,Fujimi-cho, Tachikawa city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/11	ND (Detection Limit 0.9)	ND (Detection Limit 0.6)	ND (Detection Limit 0.9)

27 Fujimidaisan Purification Plant (groundwater)

Address: 6-70,Fujimicho, Tachikawa city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/11	ND (Detection Limit 0.9)	ND (Detection Limit 0.7)	ND (Detection Limit 1)

28 Tokura Purification Plant (Tamagawa River)

Address: 261-2,Tokura, Akiruno city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/14	ND (Detection Limit 0.7)	ND (Detection Limit 0.9)	ND (Detection Limit 0.9)

29 Fukasawa Purification Plant (Tamagawa River)

Address: 560-6,Fukasawa, Akiruno city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/14	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)	ND (Detection Limit 0.9)

30 Ottsu Purification Plant (Tamagawa River)

Address: 1464-2,Ottsu, Akiruno city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/14	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)

31 Otaba Purification Plant (Tamagawa River)

Address: 498,Otoba-aza-Okunakachaya, Okutama town

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/15	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)

32 Futamatao Purification Plant (subsoil water)

Address: 5-51-1,Futamatao, Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/15	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)

33 Tanasawa Purification Plant (Tamagawa River)

Address: 583-5,Tanasawa-aza-kashiwanoki, Okutama town

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/15	ND (Detection Limit 0.8)	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)

34 Hoyacho Purification Plant (groundwater)

Address: 1-5-24,Hoya-cho,Nishitokyo city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/16	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)

35 Minamisawa Purification Plant (groundwater)

Address: 3-9-21,Minamisawa,Higashikurume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/16	ND (Detection Limit 0.8)	ND (Detection Limit 0.6)	ND (Detection Limit 0.9)

36 Nishitokyosakaecho Purification Plant (groundwater)

Address: 2-7-6,Sakae-cho, Nishitokyo city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/16	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)	ND (Detection Limit 0.9)

37 Jindaiji Purification Plant (groundwater)

Address: 5-56 Jindajiminami-cho, Chofu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/17	ND (Detection Limit 0.8)	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)

38 Izumihoncho Purification Plant (groundwater)

Address: 4-6-4,Izumihoncho, Komae city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/17	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)

39 Senkawa Purification Plant (groundwater)

Address: 3-6,Senkawa,Chofu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/17	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)	ND (Detection Limit 1)

40 Ogawa Purification Plant (groundwater)

Address: 1-847-2, Ogawa-cho, Kodaira city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/18	ND (Detection Limit 0.9)	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)

41 Kokubunjikitamachidaini Purification Plant (groundwater)

Address: 4-1-51, Kitamachi, Kokubunji city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/18	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)

42 Higashikoigakubo Purification Plant (groundwater)

Address: 2-5-8, Higashikoigakubo, Kokubunji city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/18	ND (Detection Limit 0.8)	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)

43 Takatsuki Purification Plant (subsoil water)

Address: 400, Takatsuki-cho, Hachioji city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/21	ND (Detection Limit 0.8)	ND (Detection Limit 0.7)	ND (Detection Limit 0.9)

44 Hikawa Purification Plant (Tamagawa River)

Address: 316, Hikawa-aza- ohikawa, Okutama town

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/21	ND (Detection Limit 0.9)	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)

45 Himura Purification Plant (Tamagawa River)

Address: 47, Sakai-aza- Himura, Okutama town

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/21	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)	ND (Detection Limit 0.9)

46 Motohongo Purification Plant (groundwater)

Address: 4-19-1, Motohongo, Hachioji city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/22	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)	ND (Detection Limit 1)

47 Hinatawada Purification Plant (subsoil water)

Address: 2-370, Hinatawada, Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/22	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)

48 Nariki Purification Plant (subsoil water)

Address: 7-1591-3,Nariki, Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/22	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)	ND (Detection Limit 0.9)

49 Tachikawasakaecho Purification Plant (groundwater)

Address: 5-38-5,Sakae-cho, Tachikawa city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/23	ND (Detection Limit 0.9)	ND (Detection Limit 0.9)	ND (Detection Limit 2)

50 Nakato Purification Plant (groundwater)

Address: 2-1-3,Nakato, Musashimurayama city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/23	ND (Detection Limit 0.7)	ND (Detection Limit 0.9)	ND (Detection Limit 0.8)

51 Tachikawasunagawa Purification Plant (groundwater)

Address: 6-41-1,Sunagawa-cho, Tachikawa city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/23	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)	ND (Detection Limit 0.7)

52 Haramachida Purification Plant (groundwater)

Address: 5-13-3,Haramachida,Machida city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/24	ND (Detection Limit 0.8)	ND (Detection Limit 0.9)	ND (Detection Limit 0.9)

53 Takinosawa Purification Plant (groundwater)

Address: 2-7-7, Asahi-cho, Machida city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/24	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)	ND (Detection Limit 0.9)

54 Noduta Purification Plant (groundwater)

Address: 3398,Nodutamachi, Machida city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/24	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)	ND (Detection Limit 2)

55 Shibakubo Purification Plant (groundwater)

Address: 5-9-1,Shibakubo,Nishitokyo city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/25	ND (Detection Limit 0.8)	ND (Detection Limit 0.7)	ND (Detection Limit 0.9)

56 Takiyama Purification Plant (groundwater)

Address: 6-1-1, Takiyama, Higashikurume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/25	ND (Detection Limit 0.6)	ND (Detection Limit 0.7)	ND (Detection Limit 1)

57 Kamikitadai Purification Plant (groundwater)

Address: 1-801-1,Kamikitadai, Higashiyamato city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/25	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)	ND (Detection Limit 0.8)

58 Chigasedaini Purification Plant (subsoil water)

Address: 1-69-1, Chigasemati, Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/28	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)	ND (Detection Limit 0.8)

59 Nippara Purification Plant (Tamagawa River)

Address: 1055-5,Nippara-aza- Ogawa, Okutama town

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/28	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)	ND (Detection Limit 0.7)

60 Mitakesann Purification Plant (subsoil water)

Address: 179-2,Mitakesann, Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine (Iodine 131)	Radioactive Cesium (Cesium 134)	Radioactive Cesium (Cesium 137)
2011/11/28	ND (Detection Limit 0.6)	ND (Detection Limit 0.5)	ND (Detection Limit 0.7)

1 Testing institute: Water Quality Management Center

2 ND (Not detectable): “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 0.8)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 0.8 Bq/kg, but the concentration of radioactive particles in the sample was less than 0.8 Bq/kg. Cases such as this are listed in the above chart as “ND”.

【Reference】

(Bq/kg)

	Radioactive Iodine (Iodine 131)	Radioactive Cesium
Japanese provisional (emergency) criteria for infants	100	Not specified
Japan provisional (emergency) criteria for all except infants *1	300	200

*1 Criteria value related to radioactive elements ingestion from food and drink set by Nuclear Safety Commission